F.P.L. Elettroceramica Industriale S.r.l.
Via Roma, 60 – 27053 Lungavilla (PV) ITALY
info@fplitaly.it
www.fplitaly.it

ATEX – Attestation Conformity certificate

F.P.L. S.r.l., Via Roma, 60 – 27053 Lungavilla (PV) Italy, declares on its own responsibility that

DOUBLE CABLE ENTRY EMPTY ENCLOSURE

Product id: **TTE212-AA3091**

Batch Number: **300656C**

EU type-examination certificate No.: **CESI 08 ATEX 029 U**

is in compliance with the prescription of the following European directive:

- **ATEX 2014/34/UE**

The conformity is verified under observance of the following standards:

- **EN 60079-0:2012+A11:2013**
- **EN 60079-1:2014**
- **EN 60079-7:2015+A1:2018**
- **EN 60079-31:2014**
- **IEC 60529:1989+A1:1999+A2:2013**

Notified body: **CESI S.p.A. (Milan, Italy)** id. Number **0722**

MARKING: Ex II 2G Ex db IIC Gb Ex eb IIC Gb
II 2D Ex tb IIIC Db
0722

Sign for and on behalf of:

Mr. Massimo FERRARESI
F.P.L. Administrator and Quality Manager

27053 Lungavilla, Pavia – ITALY
10/06/2020